

# CERTIFICATE OF WATER TANKER SHUTTLE ACCREDITATION

Presented to

*South Frontenac Fire Department*

Fire Station #3 (6930 Road #38, Verona) (6)  
Fire Station #4 (4808 Holleford Road at Road #38, Hartington) (6)  
Fire Station #5 (4233 Stage Coach Road, Sydenham) (6)  
Fire Station #6 (2855 Perth Road, Perth Road) (6)  
Fire Station #7 (3516 Latimer Road at Holmes Road, Inverary) (6)  
Fire Station #8 (Battersea Road at Millburn Road) (6)

**Date Test Passed: July 17<sup>th</sup> 2022**

Residential and Industrial Certification (7)

Flow Achieved: 804 I.G.P.M                      Liters Per Min: 3655  
Two (2) Hour Test Time

Signed: Melissa Rose  
Melissa Rose - Principal

This Certificate is valid for 5 years and expires July 18<sup>th</sup> 2027